

Schedule B

---

REMOTE CONTROLS

Measure Instrument and Control Apparatus	Stationary Engines														
	Water level indicator	Low-water alarm	High-water alarm	Pressure, steam or hot water indicators	Heavy oil temperature indicator	Fuel atomization pressure indicator	Water intake pressure indicator	Intake pump on/off indicator	Energy source on/off indicator	On/off indicator or differential pressure indicator for draft fans	Flame detector operation indicator <sup>**</sup>	Emergency stop	Hot water or thermal liquid temperature indicator	Flow-meter	Bearing temperature indicator or lubricating oil pressure indicator
Steam boilers	X	X	X	X	X	X	X	X	X	X	X	X			
Electric steam boilers	X	X	X	X			X	X	X			X			
Hot-water boilers		X		X	X	X	X	X*	X	X	X	X	X		
Electric hot-water boilers		X		X			X		X			X	X		
Coiled tube boilers	X	X	X	X	X	X	X	X	X	X	X	X			
Thermal liquid boilers		X			X	X		X	X	X	X	X	X	X	
Steam generators	X	X	X	X			X	X				X			
Refrigerating apparatus									X			X		X	X

\* Applicable to high-temperature and high-pressure hot-water boilers.

\*\* In the case of burners in continuous operation, gas pilot flames for oil burners, minimum flow controls for gas or oil burners and release devices for gas low-pressure may replace flame detectors.