

Provision	Amendments
	Replace the terms “inspection”, “inspector” and “inspecté” wherever they appear in the French text by “vérification”, “vérifier” and “vérifié”, respectively.
1.6	Add “and the Régie du bâtiment du Québec has approved it in accordance with section 127 of the Building Act (chapter B-1.1)” at the end of the paragraph.
	<p>Insert the following Clause:</p> <p>“4.1.6 Elevating devices exposed to the elements</p> <p>4.1.6.1</p> <p>Elevating devices exposed to the elements shall be designed and installed so that exposure to the elements does not hamper their operation.</p> <p>4.1.6.1.1</p> <p>Elevating device equipment and supports shall be protected against corrosion.</p> <p>4.1.6.1.2</p> <p>Electrical equipment and wiring shall afford a degree of protection suitable for outdoor installation, in accordance with the requirements of the <i>Canadian Electrical Code, Part I</i>.”.</p>
4.2.1	<p>Replace paragraph b) by the following:</p> <p>“b) enclosed platform lift:</p> <p>i) 7000 mm in the case of a private residence; or</p> <p>ii) 4250 mm in other cases.”.</p>
4.2.5	Insert “or a stair platform lift” after “a stair lift”.
4.4.1	<p>Insert the following at the end of Item b):</p> <p>“provided that the requirements for use by a person sitting or standing specified in the following Clauses are fulfilled:</p> <p>i) 7.7.2;</p> <p>ii) 7.7.3 by replacing “wheelchair-and-attendant platform” by “wheelchair platform”; and</p> <p>iii) 7.7.5 by replacing “wheelchair-and-attendant platform” by “wheelchair platform”;”.</p>

Provision	Amendments
4.4.2	<p>Insert the following at the end of Item b):</p> <p>“provided that the requirements for use by a person sitting or standing specified in the following Clauses are fulfilled:</p> <p>i) 7.7.2;</p> <p>ii) 7.7.3 by replacing “wheelchair-and-attendant platform” by “wheelchair platform”; and</p> <p>iii) 7.7.5 by replacing “wheelchair-and-attendant platform” by “wheelchair platform””.</p>
	<p>Add the following Clause:</p> <p>“4.8.4</p> <p>An automatic lighting of the car shall be permitted on the following conditions:</p> <p>a) the lighting may be cut only if the following three conditions exist for at least 5 minutes:</p> <p>i) the car is stopped at a landing;</p> <p>ii) the doors are closed; and</p> <p>iii) no call is made from the car or the landings.</p> <p>b) the momentary interruption of one of those conditions immediately activates the lighting;</p> <p>c) the operation of a switch or safety-related device must maintain or put into operation the lighting.”.</p>
5.1.3.1	Strike out Item c).
5.1.3.2	Replace “lb-pi” in the French text of Items b)ii) and b)iii) by “lbf”.
	<p>Add the following Clause:</p> <p>“5.2.2.3 Vertical clearance</p> <p>The vertical clearance between the bottom of the landing door or gate and the landing sill shall not exceed 10 mm (0.375 in.)”.</p>

Provision	Amendments
	<p>Add the following Clause:</p> <p>“5.2.3.6</p> <p>Interlocks certified in accordance with Clause 5.2.5.11 a) shall lock the door in the closed position with a minimum locking engagement of 7 mm (0.28 in.) of the locking elements before the interlock contacts associated with the closure of the doors or gates are closed.”.</p>
5.2.5.11	<p>Replace the portion before a) by the following: “Locking engagement shall conform to the following requirement”;</p> <hr/> <p>Strike out b).</p>
5.4.2	<p>Strike out “more than 300 mm” in the portion before Item a);</p> <hr/> <p>Replace Items f) and g) by the following:</p> <p>“f) Pits extending to the ground shall be designed to prevent entry of groundwater into the pit. A drain shall be provided to prevent accumulation of water in the pit.</p> <p>g) Drains shall comply with the applicable National Plumbing Code, and they shall be provided with a positive means to prevent water, gases, and odours from entering the runway.”.</p>
5.6.2	<p>Replace “by operation of the safeties” by “application of the safeties”.</p>
6.1.4.7	<p>Replace “prior to use or engagement of the hand-moving device” by “while the hand-moving device is used or engaged”.</p>
	<p>Add the following Clause:</p> <p>“6.1.7 Suspension means passing through floors or stairs</p> <p>Ropes and chains passing through a floor or stairway outside the hoistway enclosure shall be enclosed with a solid or openwork enclosure. Any openwork enclosure shall reject a ball exceeding 13 mm (0.5 in.) in diameter. Means for inspection shall be provided. The floor openings shall not be larger than is necessary to clear the suspension means.”.</p>

Provision	Amendments
6.2.1.1	<p>Replace Item b) by the following</p> <p>“b) aircraft cable rope of 7 x 19 construction may be used in those applications where the rope is not subjected to crushing pressures. The aircraft cable shall meet the requirements of NPFC MIL-DTL- 83420M Spec, subject to the following exceptions:</p> <p>i) nonjacketed carbon steel, tin- or zinc-coated (Type 1A) 7 × 19 construction are permitted (see Section 3.4.3.3 of NPFC MIL-DTL-83420M Spec); and</p> <p>ii) identifying colour tracer filaments are not required (see Section 3.6.2 of NPFC MIL-DTL- 83420M Spec).”.</p>
6.2.5.1	Strike out the Clause.
6.2.5.2	Strike out the Clause.
	<p>Add the following Clause:</p> <p>“6.6.2.1.4</p> <p>The sizing of the relief valve and the bypass connection shall be sufficient to permit the maximum flow of the pump without the pressure rising above 50% of the working pressure. The use of more than one relief valve shall be permitted.”.</p>
6.9 to 6.9.5.2	Strike out the Clauses.
7.2.7 to 7.2.7.2	Strike out the Clauses.
7.3.2	Replace “designed” in Item a) by “perforated and designed”.
7.6.4.1	Replace “1:10.1” in Item c) by “1:10”.
8.2.3.1	Replace “890 to 1370 mm” in Item d) by “400 to 1200 mm”.
8.3.3.1	Replace “the alarm on an enclosed vertical platform lift shall” by “the alarm and the emergency communication device on an enclosed vertical platform lift shall”.

Provision	Amendments
8.3.5	<p>Replace the second paragraph by the following: “If the call is placed automatically and is not acknowledged by a live person, the call shall be automatically redirected within 45 seconds to a location monitored by personnel who may take the appropriate actions.</p> <p>The communications shall not be transmitted to an automated answering system.”.</p>
8.5.2.3	<p>Replace the Clause by the following: “8.5.2.3 Pendant control and remote control Where a pendant control or remote control is used, an emergency stop device conforming to Clause 8.5.2.1 shall be incorporated in the pendant control and the remote control.”.</p>
Annex A	<p>Replace the portion before A.1 by the following: <i>“Annex A (mandatory) Inspection and testing”</i>;</p> <hr/> <p>Insert “and 4.1.6” after “4.1.4” in Clause A.2 a)i);</p> <hr/> <p>Insert “and 6.1.7” after “6.1.6” in Clause A.2 b)iv);</p> <hr/> <p>Insert “, 5.2.3.6,” after “5.2” in Clause A.2 c)ii);</p> <hr/> <p>Insert the following after Clause A.2 d)i): <i>“i.1) automatic lighting of the car (4.8.4)”</i>;</p> <hr/> <p>Insert “5.2.2.3,” before “7.5.4” in Clause A.2 e)iii).</p>
Annex B	<p>Replace the portion before B.1 by the following: <i>“Annex B (mandatory) Maintenance for platform lifts and stair lifts”</i>.</p>